

# Emission Test Certificate

Tuesday September 21<sup>st</sup>, 2021

Supplier: WOVEN IMAGE PTY LIMITED (37-39 Chard Road, BROOKVALE, NSW, 2100, Australia)

Sample Description: 3D Tile Series with Polycaprolactone Scatter Adhesive.

Date Tested: September 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)


Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (7 days exposure):**

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b>	<b>3D Tile Series</b>
Total Volatile Organic Compound Emission Rate limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.011 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $< 0.004 \text{ mg/m}^2/\text{hr}$
<b><i>We hereby certify that 3D Tile Series meets with requirements of Green Star Design &amp; As Built – Green Star Interiors, Green Building Council of Australia.</i></b>	



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Dr. Srikanth C. Srivatsa  
 PhD (Chemistry)  
 Scientific Consultant



Dr. Tuan Duong  
 PhD, B Eng. (Chem.)  
 Senior Consultant

**V2108071**