

# Emission Test Certificate

Friday 13<sup>th</sup> December 2019

Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW, 2100)

Sample Description: Woven Image Edge III 100% Polyester Fabric

Date Tested: December 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

## Emission Data (7 days):

<b>Green Building Council of Australia Green Star Design &amp; As Built V1.2 - 13.1.2B &amp; 13.2 Green Star Interiors V1.2 - 12.1.2B</b>	<b>Woven Image Edge III 100% Polyester Fabric</b>
Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.011 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dale Duncan  
BSc(Hons)  
Graduate Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

CV190416