

Emission Test Certificate

Thursday October 9th, 2020

Supplier: Woven Image Pty Limited (37-39 Chard Road, Brookvale, NSW, 2100, Australia)

Sample Description: Aire 100% PET (60% recycled) acoustic wall & ceiling lining Panel

Date Tested: September 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

| | |
|---|---|
| Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B | Aire 100% PET (60% recycled) acoustic wall & ceiling lining Panel |
| Total Volatile Organic Compound Emission Rate limit: $\leq 0.5 \text{ mg/m}^2/\text{hr}$ | Total Volatile Organic Compound Emission Rate: $0.016 \text{ mg/m}^2/\text{hr}$ |
| Formaldehyde Emission Rate limit: $\leq 0.1 \text{ mg/m}^2/\text{hr}$ | Formaldehyde Emission Rate: $< 0.003 \text{ mg/m}^2/\text{hr}$ |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

V2009024