

Emission Test Certificate

Friday 13th September 2024

Manufacturer	CSR Building Products Limited (376 Victoria Street, WETHERILL PARK, NSW 2164, Australia).
Brand Name	Woven Image EchoFlex Acoustic Panel.
Date Tested	August 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method	ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Woven Image EchoFlex Acoustic Panel
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.143 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr	Formaldehyde Emission rate: 0.004 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 13/09/2024

Expiry date: 13/09/2029

P24070110