

Emission Test Certificate

Thursday December 17th, 2020

Supplier: Woven Image Pty Limited (37-39 Chard Road, Brookvale, NSW, 2100, Australia)

Sample Description: Focus Print – Woven Fabric with knitted scrim and surface print
100% Polyester, 380 g/m²

Date Tested: December 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products”.

Emission Data (7 days exposure):

Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	Focus Print – Woven Fabric with knitted scrim and surface print 100% Polyester, 380 g/m²
Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.006 mg/m ² /hr
Formaldehyde Emission Rate limit: ≤ 0.1 mg/m ² /hr	Formaldehyde Emission Rate: 0.006 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Tuan Duong
B Eng. (Chem.)
Senior Consultant

V2012012