

Emission Test Certificate

Friday 29th August 2025

Manufacturer CSR Building Products Limited (376 Victoria Street, WETHERILL PARK, NSW, 21641, Australia).

Product Name Woven Image Zen Embossed IX with Mura 542

Date Tested 30th July 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D5116:2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Woven Image Zen Embossed IX with Mura 542
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.012 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m ² /hr	Formaldehyde Emission Rate: <0.006 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 29/08/2025

Expiry date: 29/08/2030

P25060071