

Emission Test Certificate

Tuesday, June 27th 2017

Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW 2100)

Sample Description: Terrain Panel/Wall product

Date Tested: June 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days exposure in environment chamber):

Global GreenTag	Terrain Panel/Wall Product
Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.017 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV170555