

Emission Test Certificate

Wednesday, January 31st 2018

Supplier: Woven Images Pty Ltd (37-39 Chard Road, Brookvale, NSW, 2100).

Sample Description: Mura Board 100% PET (68% recycled)

Date Tested: January 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia <i>Green Star Interiors V1.1 - 12.1.2B</i> <i>Green Star Design & As Built V1.1 - 13.1.2B</i></p>	<p>Mura Board 100% PET (68% recycled)</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.023 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng(Chemical Engineer)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV171222