

# Emission Test Certificate

Tuesday September 21<sup>st</sup>, 2021

Supplier: WOVEN IMAGE PTY LIMITED (37-39 Chard Road, BROOKVALE, NSW, 2100, Australia)

Sample Description: 3D Tile Series with Polycaprolactone Scatter Adhesive.

Date Tested: September 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)


Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (7 days exposure):**

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>3D Tile Series</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: <math>\leq 0.500 \text{ mg/m}^2/\text{hr}</math></p>	<p>Total Volatile Organic Compound Emission Rate: <math>0.011 \text{ mg/m}^2/\text{hr}</math></p>
<p>Formaldehyde Emission Rate limit: <math>\leq 0.100 \text{ mg/m}^2/\text{hr}</math></p>	<p>Formaldehyde Emission Rate: <math>&lt; 0.004 \text{ mg/m}^2/\text{hr}</math></p>
<p align="center"><b><i>We hereby certify that 3D Tile Series meets with requirements of Green Star Design &amp; As Built – Green Star Interiors, Green Building Council of Australia.</i></b></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Srikanth C. Srivatsa  
PhD (Chemistry)  
Scientific Consultant



Dr. Tuan Duong  
PhD, B Eng. (Chem.)  
Senior Consultant

**V2108071**