

Emission Test Certificate

Monday 27th September 2021

Supplier: WOVEN IMAGE PTY LIMITED (37-39 Chard Road, BROOKVALE, NSW, 2100, Australia)

Sample Description: 3D Tile Series with Polycaprolactone Scatter Adhesive

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers, Version 1.2: 2017 (Emission testing method for California Specification CA 01350).

Sample and Chamber conditions during test period:

Temperature	23.3°C ± 0.5°C
Humidity	49% ± 2%
Chamber Volume	50L
Chamber Flow Rate	0.857 L/min
Chamber Pressure	102.5 kPa
Product Loading	0.67 m ² /m ³
Air Exchange Rate	1.028 hr ⁻¹
Emission Collection Time	1440 min for formaldehyde and aldehydes and 120 min for Thermal Desorption tubes VOCs.
Sample Surface Area	0.031 m ²
Exposure of sample in chamber	14 days (336 hours)

Test summary: The air samples were collected from the emission chamber at 336 hours for aldehydes and VOCs. The aldehyde gases were collected on DNPH-treated silica tubes (SKC 226-119) and analysed by Ultra High-Performance Liquid Chromatography (UHPLC). The VOC gases were collected on Perkin Elmer Tenax TA Thermal Desorption tubes and analysed by ATD-GC-MS as TO-17.

Emission Data:

California Specification CA 01350	3D Tile Series
TVOC Emission Rate Limit: <0.500 mg/m ³	TVOC Emission Rate*: 0.010 mg/m ³
Formaldehyde Emission Rate Limit: <9 µg/m ³	Formaldehyde Emission Rate*: 2 µg/m ³
All other Target CREL VOCs and their emission rate are well below the maximum allowable concentrations in accordance with Table 4-1 of the standard method.	

* The stated result was calculated from an emission rate applied to the Standard Private Office Model (Table 4-4) of the standard using 33.4 m² exposed acoustical wall finish area, room volume of 30.6 m³, and ventilation rate of 0.68 hr⁻¹.



3D Tile Series sample



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V2108071