

Emission Test Certificate

Friday, 03rd January 2020


Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW, 2100, Australia)

Sample Description: Woven Image Embossed Panel

Date Tested: December 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data (7 days):

Green Building Council of Australia Green Star Design & As Built V1.2 - 13.1.2B & 13.2 Green Star Interiors V1.2 - 12.1.2B	Woven Image Embossed Panel
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.023 \text{ mg/m}^2/\text{hr}$
	



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dale Duncan
BSc (Hons)
Graduate Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V1912033