

# Emission Test Certificate

Thursday 23<sup>rd</sup> March 2022

Supplier: Woven Image Pty Ltd (37-39 Chard Road, BROOKVALE, NSW, 2100, Australia)

Sample Description: Fuji 97.7% PET (64% Recycled)/2.3% PCL Panel

Date Tested: March 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>Fuji 97.7% PET (64% Recycled)/2.3% PCL Panel</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: &lt;0.500 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.046 mg/m<sup>2</sup>/hr</p>
<p align="center">Formaldehyde Emission Rate Limit: &lt;0.100 mg/m<sup>2</sup>/hr</p>	<p align="center">Formaldehyde Emission Rate: &lt;0.008 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

**P22030142**