

Emission Test Certificate

Thursday 23th May 2019

Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW, 2100)

Sample Description: Polyolefin Upholstery Fabric

Date Tested: May 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):


<p align="center">Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p align="center">Polyolefin Upholstery Fabric</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/item/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: <0.011 mg/item/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV190416