

Emission Test Certificate

Monday, November 21st, 2011

Supplier: Woven Image Pty Ltd (37-39 Chard Rd, Brookvale, NSW 2100)

Sample Description: Pigment Printed EchoPanel AU

Date Tested: November 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Interiors IEQ-11	Pigment Printed EchoPanel AU
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: <0.093 mg/m ² /hr (24 hours)



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV111023