

# Emission Test Certificate

Thursday December 17<sup>th</sup>, 2020

Supplier: Woven Image Pty Limited (37-39 Chard Road, Brookvale, NSW, 2100, Australia)

Sample Description: Focus Print – Woven Fabric with knitted scrim and surface print  
100% Polyester, 380 g/m<sup>2</sup>

Date Tested: December 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products”.

**Emission Data (7 days exposure):**

<p><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p><b>Focus Print – Woven Fabric with knitted scrim and surface print 100% Polyester, 380 g/m<sup>2</sup></b></p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.006 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate limit: ≤ 0.1 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: 0.006 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Tuan Duong  
B Eng. (Chem.)  
Senior Consultant

V2012012