

Emission Test Certificate

Thursday, 21st March 2013

Supplier: Woven Image Pty Limited (37-39 Chard Rd, Brookvale, NSW 2100)

Sample Description: 100% PET (60% Recycled) Foil Print

Date Tested: March 2013


Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber
Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Specification	
Green Building Council of Australia Green Star Office Interiors V1.1 IEQ-11	Foil Print
Total Volatile Organic Compound emission rate <0.5 mg/m ² /hr	Total Volatile Organic Compound emission rate 0.031 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc
Consultant

CV130310