

Emission Test Certificate

Tuesday January 13th, 2008

Supplier: WovenImage

37-39 Chard Road

Brookvale NSW 2100

Sample Description: Echo Panel (100% PET – 60% Recycled)

Date Tested: December 2008

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Echo Panel

Total Volatile Organic Compound Emission Rate: <0.02 mg/m²/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be less than 0.25 mg/m³ as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV081216