

# Emission Test Certificate

Friday, 03<sup>rd</sup> January 2020


Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW, 2100, Australia)

Sample Description: Woven Image Embossed Panel

Date Tested: December 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (7 days):**

<p align="center"><b>Green Building Council of Australia Green Star Design &amp; As Built V1.2 - 13.1.2B &amp; 13.2 Green Star Interiors V1.2 - 12.1.2B</b></p>	<p align="center"><b>Woven Image Embossed Panel</b></p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.023 mg/m<sup>2</sup>/hr</p>
	



Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dale Duncan  
BSc (Hons)  
Graduate Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

**V1912033**