

Emission Test Certificate

Friday, May 27th 2016

Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW 2100)

Sample Description: Echo Tile – 100% PET (60% recycled) with adhesive backing

Date Tested: May 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Ecospecifier GreenTag	Echo Tile – 100% PET (60% recycled) with adhesive backing
Total Volatile Organic Compound Emission Rate limit: <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.015 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng (Chemical Engineer)
Laboratory Technician

CV160540a