

Emission Test Certificate

Thursday 23rd March 2022

Supplier: Woven Image Pty Ltd (37-39 Chard Road, BROOKVALE, NSW, 2100, Australia)

Sample Description: Fuji 97.7% PET (64% Recycled)/2.3% PCL Panel

Date Tested: March 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	Fuji 97.7% PET (64% Recycled)/2.3% PCL Panel
Total Volatile Organic Compound Emission Rate Limit: $<0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.046 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $<0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $<0.008 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Travis Hale
 BSc (Biotechnology)
 Consultant



Tuan Duong
 B.Eng. (Chemical)
 Consultant

P22030142