

# Emission Test Certificate

Friday, May 27<sup>th</sup> 2016

Supplier: Woven Image Pty Ltd (37-39 Chard Road, Brookvale, NSW 2100)

Sample Description: Echo Tile – 100% PET (60% recycled) with adhesive backing

Date Tested: May 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Ecospecifier GreenTag</b>	<b>Echo Tile – 100% PET (60% recycled) with adhesive backing</b>
Total Volatile Organic Compound Emission Rate limit:  <0.5mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate:  0.015 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BEng (Chemical Engineer)  
Laboratory Technician

CV160540a