

# Emission Test Certificate

Monday 06<sup>th</sup> November 2023

Supplier: Woven Image Pty Ltd (37-39 Chard Road, BROOKVALE, NSW, 2100, Australia)

Sample Description: EchoPanel 12 mm, 100% PET (80% Recycled).

Date Tested: October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

### Emission Data (24 hrs):

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b>	<b>EchoPanel 12 mm, 100% PET</b> <b>(80% Recycled)</b>
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.080 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: <0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.008 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant