

Emission Test Certificate

Saturday, 18th December 2010

Supplier: Woven Image Pty Ltd (37-39 Chard Rd, Brookvale NSW 2100 Australia)

Sample Description: WI Echo Wallcovering Printed –(100% PET, 70% Recycled), 350 gsm

Date Tested: November 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber

Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

WI Echo Wallcovering Printed

Total Volatile Organic Compound Emission Rate: <0.02 mg/m²/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m³ as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV101135