

Emission Test Certificate

Thursday, 21st March 2013

Supplier: Woven Image Pty Limited (37-39 Chard Rd, Brookvale, NSW 2100)

Sample Description: 100% PET (60% Recycled) Foil Print

Date Tested: March 2013


Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Specification Green Building Council of Australia Green Star Office Interiors V1.1 IEQ-11	Foil Print
Total Volatile Organic Compound emission rate $<0.5 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound emission rate $0.031 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc
Consultant

CV130310